



Certificate of Compliance

Certificate: 1755066 **Master Contract:** 162842 (032169_0_000)

Project: 70084724 **Date Issued:** 2016-06-17

Issued to: Mersen USA Newburyport-MA, LLC
374 Merrimac St
Newburyport, Massachusetts 01950-1998
USA
Attention: Marla Miller

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Ramana Tangirala*
Ramana Tangirala

PRODUCTS

CLASS - C622501 - FUSEHOLDER ASSEMBLIES

Cat No. "USBCC" followed with suffixes, Fuseholders, Class 'CC', 1 to 4 pole, 30A max, 600V ac max, for use with Class 'CC' fuses, intended for DIN rail mounting, provided with or without Blown Fuse indicator.

Notes:

1. These fuseholder assemblies are Certified as components for use in industrial control equipment where the suitability of the final assembly is to be determined by CSA Group.
2. Spacings are to be decided based on the product application

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 4248.4 - Fuseholders, Class CC



Supplement to Certificate of Compliance

Certificate: 1755066

Master Contract: 162842 (032169_0_000)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70084724	2016-06-17	covers correction to submittor's identification under Markings (Trade name "MERSEN" added) subsequent to FIR dated March 17, 2016.
70059585	2016-02-03	covers alternate material for Gaging Pins (Type Durethan AKV30 H2.0 réf. 901510) as covered under Item 8.
70036740	2015-09-21	covers alternate palting (Silver to Tin) for Fuse Clips as covered under Item 3
2717651	2014-04-07	covers revised Factory Test sampling plan(a minimum of 1 sample per shift).
2541765	2012-07-06	covers correction under Markings -replace "Use Class J fuses" to "Use Class CC fuses"
2378121	2011-01-10	Covers revised factory test procedure.
1766984	2006-04-19	Covers Audit testing
1755066	2006-01-24	Cat No. USBCC, Class "CC" Fuseholder Assembly, 30A, 600V ac.