



中国国家强制性产品认证证书

证书编号：2013010308612624

委托人名称、地址

美尔森电气保护系统(上海)有限公司
上海市松江区书山路55弄6、7、8号

生产者(制造商)名称、地址

美尔森电气保护系统(上海)有限公司
上海市松江区书山路55弄6、7、8号

生产企业名称、地址

美尔森电气保护系统(上海)有限公司
上海市松江区书山路55弄6、7、8号

产品名称和系列、规格、型号

半导体设备保护用熔断体

□URD33□□□: Un:AC450V, AC500V, AC550V, AC600V, AC690V; In: 450A, 500A, 550A, 630A, 700A, 800A, 900A, 1000A, 1100A, 1250A, 1400A/690V; 1500A, 1600A, 1800A/600V; 2000A/550V; 2250A/500V; 2500A/450V;
额定分断能力:100kA; 分断范围和使用类别: aR; 型号解释见附件

产品标准和技术要求

GB/T 13539.4-2016

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，
特发此证。

发证日期：2018年05月16日 有效期至：2023年05月13日
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2013年05月13日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任：



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2013010308612624

NAME AND ADDRESS OF THE APPLICANT

Mersen Shanghai Co.,Ltd.
No.6、7、8, Lane 55, Shushan Road, Songjiang District, Shanghai City, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Mersen Shanghai Co.,Ltd.
No.6、7、8, Lane 55, Shushan Road, Songjiang District, Shanghai City, P.R.China

NAME AND ADDRESS OF THE FACTORY

Mersen Shanghai Co.,Ltd.
No.6,7,8, Lane 55, Shushan Road, Shanghai, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Fuse-links for the protection of semiconductor devices

□URD33□□□: Un:AC450V, AC500V, AC550V, AC600V, AC690V; In: 450A, 500A, 550A, 630A, 700A, 800A, 900A, 1000A,1100A, 1250A, 1400A/690V;1500A, 1600A, 1800A/600V; 2000A/550V; 2250A/500V; 2500A/450V; I1: 100kA; Breaking Range and Utilization Category: aR; See the appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 13539.4-2016

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: May.16,2018

Valid until: May.13,2023

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: May.13,2013

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书


附 录

第 1 页 共 3 页

证书编号: 2013010308612624

纸 号: 1949411

型号解释:



xx	URD	33	xx	xx
电压/100 Voltage/100	曲线类型 Type of curve	陶瓷管尺寸 Size of body	端子 TTF-平端安装(公制螺纹) TTI-平端安装(英制螺纹) KI-美式安装(短刀片) LI-美式安装(长刀片) EF-勾型安装(E向刀片) D08A-勾型安装(短刀片) D11A-勾型安装(长刀片) PA-刀型插入式	电流 Rating

注: 此附录与证书同时使用时有效。



主 任:



中国质量认证中心