



中国国家强制性产品认证证书

证书编号: 2016010308930380

委托人名称、地址

美尔森电气保护系统(上海)有限公司
上海市松江区书山路55弄6,7,8号

生产者(制造商)名称、地址

美尔森电气保护系统(上海)有限公司
上海市松江区书山路55弄6,7,8号

生产企业名称、地址

美尔森电气保护系统(上海)有限公司
上海市松江区书山路55弄6,7,8号

产品名称和系列、规格、型号

半导体设备保护用熔断体

□URD72□□; Un:AC850V, AC1000V, AC1100V; In:630A, 700A, 800A/1100V,
700A, 800A, 900A/1000V, 1000A/850V; 额定分断能力:100kA; 分断范围和使用类别:aR;
型号解释详见附件

产品标准和技术要求

GB/T 13539.4-2016

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求,特发此证。

发证日期: 2017年03月14日

有效期至: 2022年03月14日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1637364



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2016010308930380

NAME AND ADDRESS OF THE APPLICANT

Mersen Shanghai Co., Ltd.
No. 6, 7, 8, Lane 55, Shushan Road, Shanghai, P. R. China

NAME AND ADDRESS OF THE MANUFACTURER

Mersen Shanghai Co., Ltd.
No. 6, 7, 8, Lane 55, Shushan Road, Shanghai, P. R. China

NAME AND ADDRESS OF THE FACTORY

Mersen Shanghai Co., Ltd.
No. 6, 7, 8, Lane 55, Shushan Road, Shanghai, P. R. China

NAME, MODEL AND SPECIFICATION

Fuse-links for the protection of semiconductor devices

□URD72□□; Un:AC850V, AC1000V, AC1100V; In:630A, 700A, 800A/1100V,
700A, 800A, 900A/1000V, 1000A/850V; Rated breaking capacity:100kA; Breaking
Range and Utilization Category:aR;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 13539.4-2016

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification (REF NO. CNCA-C03-02:2014).

Date of issue: Mar.14, 2017 Date of expiry: Mar.14, 2022

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

Q 1637364



中国国家强制性产品认证证书


附录:

第 1 页 共 2 页

证书编号: 2016010308930380

纸号: 1637364

型号解释:



xx	URD	72	xx	xx
电压/100 Voltage/100	曲线类型 Type of curve	陶瓷管尺寸 Size of body	端子 TTF-平端安装 (公制螺纹) TTI-平端安装 (英制螺纹) LI-美式安装 (长刀片) EF-勾型安装 (E 向刀片) PA-刀形安装 (插入式) D11A-勾型安装 (长刀片)	电流 Rating

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

